

Project	Bedford Beverly Brownfield	Report No.	58
	Site		
BCP Site	BCP Site No. C224384	Date	12/28/2023
Location	2359 and 2360 Bedford	File No.	0205432
	Avenue, Brooklyn, NY		
Client	Bedford Beverly Acquisitions	Temperature	52-47°F
	LLC, Maman Contracting		
	(Maman), International		
	Concrete		
Contractor	Haley & Aldrich	Wind Direction	NE to SW, 11 mph
Weather	Cloudy	Personnel on	E. Nunez, C. Evertz, D.
		Site	Djombalic
Humidity	90%	Time on Site	6:30 am to 3:30 pm

Haley & Aldrich of New York (Haley & Aldrich) was present to document implementation of the Remedial Action Work Plan (RAWP) prepared by Haley & Aldrich currently under review by NYSDEC and the NYSDEC-approved Change of Use dated 17 August 2023 to begin support of excavation work. Site observations are summarized below.

Daily Observations:

- Contractor (International Concrete) continued support of excavation (SOE) installation along the perimeter of Lots 14 and 53.
- Contractor (International Concrete) continued loading asphalt and C&D for transport and disposal off-site.

Waste Disposal/Backfill Import Tracking:

Material Export:

• Soil/Fill disposal is summarized below:

	S Solly in disposal is summarized below.										
	Facility: Bayshore		Facility: P Park NJ		Facility: Keystone		Facility: Posillico				
	Soil Management,		LLC, Pros	pect Park,	pect Park, Trade Center		Materials Permitted				
	Keasbey, NJ (Non-		NJ (Non-	-Haz Soil)	Fairless Hills, PA		Wash Plant, LLC,				
	Haz Soil)				(Non-Haz Soil)		Farmingdale, NY		Totals:		
							(Non-Haz Soil)				
Today:	42	840 CY	0	0 CY	0 Loads	0 CY	39 Loads	780 CY	81 Loads	1,620 CY	
	Loads		Loads							,	
<u>Total:</u>	<u>254</u>	5,080 CY	<u>727</u>	<u>14,540</u>	<u>262</u>	5,240 CY	<u>136</u>	2 720 CV	<u>1,379</u>	<u>27,580</u>	
	Loads	<u>5,060 CT</u>	Loads	CY	Loads	<u>5,240 CT</u>	<u>Loads</u>	<u>2,720 CY</u>	<u>Loads</u>	<u>CY</u>	

*Note, 1 truck estimated at 20 cubic yards. Final tonnages will be present in the Final Engineering Report (FER)

• Asphalt disposal is summarized below:

		Facility: Flush Recycling, F (Aspl	lushing NY	Facility: Materials, F PA (As	-				
			•			Totals:			
	Today:	0 Loads	0 CY	6 Loads	120 CY	6 Loads	120 CY		
	<u>Total:</u>	<u>117 Loads</u>	<u>2,340 CY</u>	27 Loads	<u>540 CY</u>	<u>144 Loads</u>	<u>2,880 CY</u>		
*Not	*Note, 1 truck estimated at 20 cubic yards. Final tonnages will be present in the Final Engineering Report (FER)								



0

(C&D disposal is summarized below:	

	Facility:	Mount							
	Mate	rials,							
	Fairless I	Hills, PA							
	(Non-Haz	Concrete)	Tota	ls:					
Today:	3 Loads	60 CY	3 Loads	60 CY					
Total:	86 Loads	1,720 CY	86 Loads	1,720 CY					

*Note, 1 truck estimated at 20 cubic yards. Final tonnages will be present in the Final Engineering Report (FER)

Material Import:

• Material import is summarized below:

		Facility: Mo	ount Hope	Facility: M	ount Hope			
		Qua	rry,	Qua	arry,			
		Wharton, NJ		Wharton, NJ				
		(ASTM	#57)	(ASTM #3)		Totals:		
Toda	ay:	0 Loads	0 CY	0 loads	0 CY	0 Loads	0 CY	
<u>Tota</u>	al:	<u>5 Loads</u> <u>100 CY</u>		<u>15 loads</u> <u>300 CY</u>		20 Loads	<u>400 CY</u>	

*Note, 1 truck estimated at 20 cubic yards. Final tonnages will be present in the Final Engineering Report (FER)

Samples Collected:

• No samples taken.

CAMP Activities:

 Air monitoring during ground-intrusive activities was performed at four locations during ground intrusive work from 6:30 am to 3:00 pm. No 15-minute average concentration of volatiles organic compounds (VOCs) or particulate 15-minute average concentration of matter smaller than 10 microns in diameter (PM10) exceeded the action levels. No visible dust was observed leaving the site perimeter.



Activities Planned for Coming Week:

- Contractor (International Concrete) will continue stockpiling soil on the perimeter of Lot 14 for disposal.
- Contractor (International Concrete) will begin stockpiling soil on the perimeter of Lot 53 for disposal.
- Contractor (International Concrete) will continue installing H piles as part of SOE installation on the perimeter of the site.
- Contractor (International Concrete) will continue transportation and disposal of soil/fill to an approved facility.



Site Photographs:




Photo 1: View of soil loadout on Lot 14, facing south-southwest.



Photo 2: View of the contractor grading Site soils in Lot 14, facing west.





2360 Bedford Avenue, Brooklyn NY

Air Monitoring Log

Date: 2023-12-28

Personnel :	D. Djombalic, E. Nunez & C. Evertz
Weather :	Cloudy
Humidity :	90%
Wind Direction :	NE to SW, 11 mph

Particulate Background (ug/m3) : 0.723 PID Background (ppm) : 0.0

Action Levels : <u>Downwind perimeter of work area above background levels</u>

PID (ppm): > 5 ppm for the 15-min average

Dust (ug/m3) : > 150 for the 15-min average

Minute of Time	Avg. PM10 (Station1)	Avg. PM10 (Station2)	Avg. PM10 (Station3)	Avg. PM10 (Station4)	Avg. VOC(Station1)	Avg. VOC(Station2)	Avg. VOC(Station3)	Avg. VOC(Station4)	Odors	Notes Activities/ Additional Monitoring
07:00		4.212		0.723		0.0		0.0		
07:15		1.946		0.636		0.0		0.0		
07:30		1.394		0.725		0.0		0.0		
07:45		2.826		2.175		0.0		0.0		
08:00		3.501		3.040		0.0		0.0		
08:15	4.308	3.492	3.980	2.910	0.0	0.0	0.0	0.0		
08:30	3.702	5.044	3.436	3.064	0.0	0.0	0.0	0.0		
08:45	3.560	10.800	3.502	3.416	0.0	0.0	0.0	0.0		
09:00	3.923	4.766	3.865	3.454	0.0	0.0	0.0	0.0		
09:15	3.703	4.778	3.322	3.251	0.0	0.0	0.0	0.0		
09:30	3.832	5.051	3.129	3.023	0.0	0.0	0.0	0.0		
09:45	3.653	4.406	3.203	3.067	0.0	0.0	0.0	0.0		
10:00	3.841	8.495	3.355	3.107	0.0	0.0	0.0	0.0		
10:15	2.979	6.744	2.912	2.752	0.0	0.0	0.0	0.0		
10:30	2.539	2.790	2.551	2.326	0.0	0.0	0.0	0.0		
10:45	2.707	2.573	2.287	2.314	0.0	0.0	0.0	0.0		

2360 Bedford Avenue, Brooklyn NY

Air Monitoring Log

Minute of Time	Avg. PM10 (Station1)	Avg. PM10 (Station2)	Avg. PM10 (Station3)	Avg. PM10 (Station4)	Avg. VOC(Station1)	Avg. VOC(Station2)	Avg. VOC(Station3)	Avg. VOC(Station4)	Odors	Notes Activities/ Additional Monitoring
11:00	2.118	2.180	1.732	1.9	0.0	0.0	0.0	0.0		
11:15	1.626	1.734	1.377	1.6	0.0	0.0	0.0	0.0		
11:30	1.749	1.743	1.417	2.3	0.0	0.0	0.0	0.0		
11:45	1.566	1.900	1.420	1.6	0.0	0.0	0.0	0.0		
12:00	1.555	1.676	1.352	1.7	0.0	0.0	0.0	0.0		
12:15	1.853	1.991	1.870	1.9	0.0	0.0	0.0	0.0		
12:30	1.995	2.198	2.114	2.0	0.0	0.0	0.0	0.0		
12:45	3.379	2.471	1.993	2.3	0.0	0.0	0.0	0.0		
13:00	4.404	2.613	1.687	2.9	0.0	0.0	0.0	0.0		
13:15		2.169		2.8		0.0		0.0		
13:30		3.687		2.8		0.0		0.0		
13:45		2.367		2.2		0.0		0.0		
14:00		2.370		2.6		0.0		0.0		
14:15		2.481		3.9		0.0		0.0		
14:30		3.224		2.5		0.0		0.0		
14:45		4.064		2.6		0.0		0.0		