



December 15, 2014

Brent Curtis O'Dell, P.E.
AMEC Environmental & Infrastructure, Inc.
200 American Metro Blvd, Suite 113
Hamilton, NJ 08619

Emily Lloyd
Commissioner

**RE: Dewatering at 37-30 & 37-80 REVIEW AVENUE
Block #312, Lot #s 41 & 69
Borough of Queens**

James J. Roberts, P.E.
Deputy Commissioner

59-17 Junction Boulevard
Flushing, NY 11373-5108

**Bureau of Water and
Sewer Operations**

jroberts@dep.nyc.gov

Dear Mr. O'Dell:

We are in receipt of your revised dewatering submission dated November 14, 2014, requesting permission to temporarily discharge up to 36,000 gallons per day (gpd) of groundwater continuously for a period of one year, during remediation through an existing 6" diameter (dia.) connection to the 12" dia. combined sewer in Review Avenue between 37th Street and Railroad Avenue in the Borough of Queens.

Based upon the information, schematic and analytical data submitted, you are hereby authorized to obtain DEP permit to temporarily discharge, during remediation up to 36,000 gallons per day (gpd) of groundwater for a period of one year at the rate not to exceed 0.06 cubic feet per second (cfs) as specified in your submission to the combined sewer at the above mentioned location. The Industrial Inspections and Permitting Section have given you approval for this dewatering discharge (C-5652) by the letter dated October 8, 2014.

The discharger shall indemnify and hold the City harmless for any damage or liability incurred by the City due to the dewatering and in the event that the discharger results in overloading the capacity of the discharge sewer. See the copy of the special Indemnity Agreement attached, to be signed and filed with the discharge permit application.

Please note that no dewatering permit will be issued until the payment is made to the Bureau of Customer Services for groundwater discharge into the New York City Wastewater System in accordance with the Water and Wastewater Rate Schedule established by the New York Water Board.

If you have any further questions concerning this matter, please contact Mr. Suresh Kumar at (718) 595-5205.

Very truly yours,

A handwritten signature in blue ink, appearing to read 'James A. Luke', with a large, stylized flourish extending to the right.

James A. Luke, P.E., Chief
Permitting & Compliance

Special Indemnity Agreement
For temporary groundwater discharge in the City sewer system

(Present Date)

Commissioner
Department of Environmental Protection
59-17 Junction Boulevard
Corona, NY 11368

Location: 37-30 REVIEW AVENUE
LONG ISLAND CITY
QUEENS, NYC


Re: **Dewatering Permit**

Dear Commissioner:


(Property Owner) hereby agrees to indemnify and to save harmless, to the fullest extent permitted by law, the City of New York, the New York City Department of Environmental Protection (hereinafter referred to as the "City") and their respective offices, representatives, agencies, contractors, servants, and employees from and against any and all claims, suits, actions, proceedings, and losses that may arise after the date of this agreement from the construction, maintenance, operation, or use of any sewer connection (direct or indirect) to the City Sewer System for the purpose of dewatering.

In addition it is noted that the City is held harmless due to any harmful side effects of lowering the Water Table such as but not limited to impact of drawdown on the perimeter of the site, salt water intrusion, movement of contaminated groundwater, backflow due to surcharge of outlet sewer and effect on any wetlands.


Professional Engineer, STAMP & Signature

Very truly yours,

(Property Owner's Signature)
Name (print)
Address

To Be Notarized


ANNE MARIE MARRON
NOTARY PUBLIC OF NEW JERSEY
I.D. # 2431652
My Commission Expires 3/25/2018

Anne Marron
7/1/15