

**OCL Analytical Services**  
35 Goshen Turnpike  
Bloomingburg, New York 12721

# Analytical Results

OCL Sample No: **236168**

Page 1 of 1

Method: EPA 904.0

Analyte	Result	Units	MCL	DL	By	Notes	Prepared	Analyzed
Radium 226	0.75+/-0.33	pCi/L		2.00		BNCHC	02/18/2008 11:30	02/22/2008 00:00

GT = greater than  
LT = less than  
ND = not detected

MCL = maximum contaminant level  
DL = detection level

ELCD = Electrolytic Conductivity Detector (QC)  
PID = Photoionization Detector (QC)

Analysis by Eastern Lab Services #11218 (unless otherwise noted)

Printed on: 3/10/2008

**OCL Analytical Services**  
 35 Goshen Turnpike  
 Bloomingburg, New York 12721

# Analytical Results

OCL Sample No: 239637-01

Page 1 of 1

Method: EPA 904.0

Analyte	Result	Units	MCL	DL	By	Notes	Prepared	Analyzed
Radium-228	-0.15	pCi/L		0.84	CCA		06/13/2008 00:00	06/13/2008 00:00

GT = greater than  
 LT = less than  
 ND = not detected

MCL = maximum contaminant level  
 DL = detection level  
 Analysis by Eastern Lab Services #11216 (unless otherwise noted)

ELCD = Electrolytic Conductivity Detector (QC)  
 PID = Photoionization Detector (QC)

Printed on: 6/18/2008

**JCL Analytical Services**

35 Goshen Turnpike  
Bloomington NY 12721

Phone 845-733-1557

Fax 845-733-1944

Web odanalytical.com

**Certificate of Analysis**

Village of Florida  
Attn: Jim Kennedy  
P.O. Box 505, 33 S. Main St.  
Florida, NY 10921

Project NY3503527  
Date Reported 11/26/2008  
Date Received 11/12/2008  
Date Complete 11/26/2008

Sample Number 244657-01  
Federal ID NY3503527  
Description Village of Florida  
Location Entry Point  
Sample Point

Date Sampled 11/12/08 7:00  
Sampler J. Kennedy

Test	Result	Units	Method	MCL	Prep Date	Test Date	Analyst	Qualifiers
<b>525.2 SVOC</b>								
Heptachlor	< 0.00010	mg/L	EPA 525.2	0.0004	11/21/08 18:53	11/21/08 18:53	RHH-SA	
Heptachlor epoxide	< 0.00010	mg/L	EPA 525.2	0.0002	11/21/08 18:53	11/21/08 18:53	RHH-SA	
Hexachlorobenzene	< 0.00010	mg/L	EPA 525.2	0.001	11/21/08 18:53	11/21/08 18:53	RHH-SA	
Hexachlorocyclopentadiene	< 0.00010	mg/L	EPA 525.2	0.05	11/21/08 18:53	11/21/08 18:53	RHH-SA	
Methoxychlor	< 0.00010	mg/L	EPA 525.2	0.04	11/21/08 18:53	11/21/08 18:53	RHH-SA	
Metolachlor	< 0.00104	mg/L	EPA 525.2	0.05	11/21/08 18:53	11/21/08 18:53	RHH-SA	
Metribuzin	< 0.00104	mg/L	EPA 525.2	0.05	11/21/08 18:53	11/21/08 18:53	RHH-SA	
Propachlor	< 0.00104	mg/L	EPA 525.2	0.05	11/21/08 18:53	11/21/08 18:53	RHH-SA	
Simazine	< 0.00010	mg/L	EPA 525.2	0.004	11/21/08 18:53	11/21/08 18:53	RHH-SA	
<b>531.1 Carbamates</b>								
3-Hydroxycarbofuran	< 0.00100	mg/L	EPA 531.1		11/18/08 7:00	11/18/08 7:00	IC-SA	
Aldicarb	< 0.00100	mg/L	EPA 531.1	0.003	11/18/08 7:00	11/18/08 7:00	IC-SA	
Aldicarb sulfone	< 0.00100	mg/L	EPA 531.1	0.002	11/18/08 7:00	11/18/08 7:00	IC-SA	
Aldicarb sulfoxide	< 0.00100	mg/L	EPA 531.1	0.004	11/18/08 7:00	11/18/08 7:00	IC-SA	
Carbaryl	< 0.00100	mg/L	EPA 531.1		11/18/08 7:00	11/18/08 7:00	IC-SA	
Carbofuran	< 0.00100	mg/L	EPA 531.1	0.04	11/18/08 7:00	11/18/08 7:00	IC-SA	
Methomyl	< 0.00100	mg/L	EPA 531.1		11/18/08 7:00	11/18/08 7:00	IC-SA	
Oxamyl	< 0.00100	mg/L	EPA 531.1	0.2	11/18/08 7:00	11/18/08 7:00	IC-SA	

**OL Analytical Services**

35 Goshen Turnpike  
Bloomingburg NY 12721

Phone 845-733-1557

Fax 845-733-1944

Web odanalytical.com

**Certificate of Analysis**

Village of Florida  
Attn: Jim Kennedy  
P.O. Box 505, 33 S. Main St.  
Florida, NY 10921

Project NY3503527  
Date Reported 11/26/2008  
Date Received 11/12/2008  
Date Complete 11/26/2008

Sample Number 244657-01  
Federal ID NY3503527  
Description Village of Florida  
Location Entry Point  
Sample Point

Date Sampled 11/12/08 7:00  
Sampler J. Kennedy

Test	Result	Units	Method	MCL	Prep Date	Test Date	Analyst	Qualifiers
<b>504.1 EDB/DBCP</b>								
1,2-Dibromo-3-chloropropane	< 0.00001	mg/L	EPA 504.1	0.0002	11/18/08 22:33	11/18/08 22:33	CPH-SA	
1,2-Dibromoethane (EDB)	< 0.00001	mg/L	EPA 504.1	0.00005	11/18/08 22:33	11/18/08 22:33	CPH-SA	
<b>508 SOC PestPCBs</b>								
Chlordane (tech)	< 0.00010	mg/L	EPA 508	0.002	11/21/08 22:53	11/21/08 22:53	CPH-SA	
PCBs as Aroclors (screen)	Absent	mg/L	EPA 508	0.0005	11/21/08 22:53	11/21/08 22:53	CPH-SA	
Toxaphene	< 0.00025	mg/L	EPA 508	0.003	11/21/08 22:53	11/21/08 22:53	CPH-SA	
<b>515.3 NY Herb</b>								
2,4,5-TP (Silvex)	< 0.0003	mg/L	EPA 515.3	0.01	11/19/08 8:33	11/19/08 8:33	JJ6-CV	
2,4-D	< 0.0005	mg/L	EPA 515.3	0.05	11/19/08 8:33	11/19/08 8:33	JJ6-CV	
Dalapon	< 0.0030	mg/L	EPA 515.3	0.2	11/19/08 8:33	11/19/08 8:33	JJ6-CV	
Dicamba	< 0.0003	mg/L	EPA 515.3		11/19/08 8:33	11/19/08 8:33	JJ6-CV	
Dinoseb	< 0.0005	mg/L	EPA 515.3	0.007	11/19/08 8:33	11/19/08 8:33	JJ6-CV	
Pentachlorophenol	< 0.0003	mg/L	EPA 515.3	0.001	11/19/08 8:33	11/19/08 8:33	JJ6-CV	
Picloram	< 0.0003	mg/L	EPA 515.3	0.5	11/19/08 8:33	11/19/08 8:33	JJ6-CV	
<b>525.2 SVOC</b>								
Alachlor	< 0.00010	mg/L	EPA 525.2	0.002	11/21/08 18:53	11/21/08 18:53	RHH-SA	
Aldrin	< 0.00010	mg/L	EPA 525.2	0.005	11/21/08 18:53	11/21/08 18:53	RHH-SA	
Atrazine	< 0.00010	mg/L	EPA 525.2	0.003	11/21/08 18:53	11/21/08 18:53	RHH-SA	
Benzo (a) pyrene	< 0.00010	mg/L	EPA 525.2	0.0002	11/21/08 18:53	11/21/08 18:53	RHH-SA	
Butachlor	< 0.00104	mg/L	EPA 525.2	0.05	11/21/08 18:53	11/21/08 18:53	RHH-SA	
Di(2-ethylhexyl)adipate	< 0.00208	mg/L	EPA 525.2	0.4	11/21/08 18:53	11/21/08 18:53	RHH-SA	S
Di(2-ethylhexyl)phthalate	< 0.00208	mg/L	EPA 525.2	0.006	11/21/08 18:53	11/21/08 18:53	RHH-SA	S
Dieldrin	< 0.00010	mg/L	EPA 525.2	0.005	11/21/08 18:53	11/21/08 18:53	RHH-SA	
Endrin	< 0.00010	mg/L	EPA 525.2	0.002	11/21/08 18:53	11/21/08 18:53	RHH-SA	
HCH-gamma (Lindane)	< 0.00010	mg/L	EPA 525.2	0.0002	11/21/08 18:53	11/21/08 18:53	RHH-SA	

CV - Benchmark Center Valley NELAP 11827  
SA - Benchmark Sayre NELAP 11216

OCL NELAP 10510

Page 1 of 3

**Village Of Florida Inc.**  
**P.O. Box 505, 33 South Main Street,**  
**Florida, N.Y. 10921**  
**Water Treatment Facilities**  
 845-651-7630 Plant 845-651-7815 Village Hall

Date  
 10/23/2006

	Location	Copper mg/l	Lead mg/l	
1	10 Dussenbury	ND	ND	
2	165 S.Main	ND	ND	
3	48 Werner Ave.	ND	ND	
4	24 Houston Ave.	ND	ND	
5	6 Cynthia Crt.	ND	ND	
6	21 Rose St.	ND	ND	
7	11 Rose St.	ND	ND	
8	10 Robert Dr.	ND	ND	
9	4 Robert Dr.	ND	ND	
10	70 Ferris Ave.	ND	ND	
11	2 Cohen Circle	ND	ND	
12	33 South Main St.	ND	ND	
13	Valley View	ND	ND	Valley View Locations
14	Marina's	ND	ND	SS Break Room
15	Stop n Wash	ND	ND	
16	8 N.Main St.	ND	ND	
17	64 Ferris St.	ND	ND	
18	68 Ferris St.	ND	ND	
19	158 N. Main St.	ND	ND	
20	69 N.Main St.	ND	ND	
21	27 Rose St.	ND	0.002	
22	2 Robert Dr.	ND	0.002	
23	63 Jayne St.	ND	0.003	
24	5 Robert Dr.	ND	0.0032	
25	61 Jayne St.	ND	0.005	
26	2 Roosevelt Dr.	ND	0.0055	
27	Valley View	ND	0.0068	90% Couser
28	Valley View	ND	0.007	Sewer Plant
29	Valley View	ND	0.076	Well House Sink
30	Valley View	ND	0.23	Party Bldg. Dining

**OCL Analytical Services**

35 Goshen Turnpike  
Bloomington, NY 12721

Phone 845-733-1557

Fax 845-733-1944

Web oclanalytical.com

**Certificate of Analysis**

Village of Florida  
Attn: Jim Kennedy  
P.O. Box 505, 33 S. Main St.  
Florida, NY 10921

Project NY3503527  
Date Reported  
Date Received 5/11/2009  
Date Complete 5/22/2009

Sample Number 248115-01  
Federal ID NY3503527  
Description Village of Florida  
Location Entry Point  
Sample Point

Date Sampled 05/10/09 9:00  
Sampler J. Kennedy

Test	Result	Units	Method	MCL	Prep Date	Test Date	Analyst	Qualifiers
<b>502.2 NY VOCs</b>								
trans-1,3-Dichloropropene	< 0.0005	mg/L	EPA 524.2	.005	05/13/09 22:19	05/13/09 22:19	DN-CV	
<b>IOCTOTAL</b>								
Arsenic, As	< 0.0005	mg/L	EPA 200.8	0.01	05/19/09 17:16	05/19/09 17:16	JRA-CV	
Barium, Ba	0.0040	mg/L	EPA 200.8	2.00	05/15/09 17:30	05/15/09 17:30	JRA-CV	
Cadmium, Cd	< 0.0005	mg/L	EPA 200.8	0.005	05/19/09 17:16	05/19/09 17:16	JRA-CV	
Chromium, Cr	< 0.0020	mg/L	EPA 200.8	0.10	05/15/09 17:30	05/15/09 17:30	JRA-CV	
Mercury, Hg	< 0.0002	mg/L	EPA 245.1	0.002	05/18/09 15:57	05/18/09 15:57	RMD-C	
Selenium, Se	< 0.0030	mg/L	EPA 200.8	0.05	05/15/09 17:30	05/15/09 17:30	JRA-CV	
Antimony, Sb	< 0.0005	mg/L	EPA 200.8	0.006	05/19/09 17:16	05/19/09 17:16	JRA-CV	
Beryllium, Be	< 0.0005	mg/L	EPA 200.8	0.004	05/19/09 17:16	05/19/09 17:16	JRA-CV	
Nickel, Ni	< 0.0005	mg/L	EPA 200.8		05/15/09 17:30	05/15/09 17:30	JRA-CV	
Thallium, Tl	< 0.0005	mg/L	EPA 200.8	0.002	05/19/09 17:16	05/19/09 17:16	JRA-CV	
Fluoride	< 0.200	mg/L	EPA 340.2	2.2		05/21/09 0:00	SM	
Cyanide	< 0.004	mg/L	SM4500CN CI	0.2	05/14/09 14:37	05/14/09 14:37	KMS	

Approved By

*David M Kennedy*

David Kennedy  
Technical Director

**OCL Analytical Services**

35 Goshen Turnpike  
 Bloomingburg NY 12721

Phone 845-733-1557  
 Fax 845-733-1944  
 Web odanalytical.com

**Certificate of Analysis**

Village of Florida  
 Attn: Jim Kennedy  
 P.O. Box 505, 33 S. Main St  
 Florida, NY 10921

Project  
 Date Reported 6/19/2008  
 Date Received 6/3/2008  
 Date Complete 6/19/2008

Sample Number 240187-01  
 Federal ID 3503527  
 Description Village of Florida  
 Location Entry Point  
 Sample Point

Date Sampled 06/03/08 7:00  
 Sampler J. Kennedy

Test	Result	Units	Method	MCL	Prep Date	Test Date	Analyst	Qualifiers
<b>IOCTOTAL</b>								
Arsenic, As	< 0.0005	mg/L	EPA 200.8	0.05	06/13/08 21:12	06/13/08 21:12		
Barium, Ba	0.0036	mg/L	EPA 200.8	2.00	06/13/08 21:12	06/13/08 21:12		
Cadmium, Cd	< 0.0005	mg/L	EPA 200.8	0.005	06/13/08 21:12	06/13/08 21:12		
Chromium, Cr	< 0.0020	mg/L	EPA 200.8	0.10	06/13/08 21:12	06/13/08 21:12		
Mercury, Hg	< 0.0002	mg/L	EPA 245.1	0.002	06/11/08 14:07	06/11/08 14:07		
Selenium, Se	< 0.0030	mg/L	EPA 200.8	0.05	06/13/08 21:12	06/13/08 21:12		
Antimony, Sb	< 0.0005	mg/L	EPA 200.8	0.006	06/13/08 21:12	06/13/08 21:12		
Beryllium, Be	< 0.0005	mg/L	EPA 200.8	0.004	06/13/08 21:12	06/13/08 21:12		
Nickel, Ni	< 0.0005	mg/L	EPA 200.8		06/13/08 21:12	06/13/08 21:12		
Thallium, Tl	< 0.0005	mg/L	EPA 200.8	0.002	06/17/08 11:20	06/17/08 11:20		
Fluoride	< 0.200	mg/L	EPA 340.2	2.2		06/10/08 0:00	LM	
Sulfate	12.0	mg/L	EPA 375.4	250		06/05/08 0:00	LM	
Cyanide (total)	< 0.010	mg/L	EPA 335.4	0.2	06/17/08 15:00	06/17/08 15:00		

Approved By David M Kennedy  
 David Kennedy  
 Technical Director

**OCL Analytical Services**

35 Goshen Turnpike  
 Bloomingburg NY 12721

Phone 845-733-1557  
 Fax 845-733-1944  
 Web odanalytical.com

**Certificate of Analysis**

Village of Florida  
 Attn: Jim Kennedy  
 P.O. Box 505, 33 S. Main St.  
 Florida, NY 10921

Project NY3503527  
 Date Reported  
 Date Received 5/11/2009  
 Date Complete 5/22/2009

Sample Number 248115-01  
 Federal ID NY3503527  
 Description Village of Florida  
 Location Entry Point  
 Sample Point

Date Sampled 05/10/09 9:00  
 Sampler J. Kennedy

Test	Result	Units	Method	MCL	Prep Date	Test Date	Analyst	Qualifiers
<b>502.2 NY VOCs</b>								
trans-1,3-Dichloropropene	< 0.0005	mg/L	EPA 524.2	.005	05/13/09 22:19	05/13/09 22:19	DN-CV	
<b>IOCTOTAL</b>								
Arsenic, As	< 0.0005	mg/L	EPA 200.8	0.01	05/19/09 17:16	05/19/09 17:16	JRA-CV	
Barium, Ba	0.0040	mg/L	EPA 200.8	2.00	05/15/09 17:30	05/15/09 17:30	JRA-CV	
Cadmium, Cd	< 0.0005	mg/L	EPA 200.8	0.005	05/19/09 17:16	05/19/09 17:16	JRA-CV	
Chromium, Cr	< 0.0020	mg/L	EPA 200.8	0.10	05/15/09 17:30	05/15/09 17:30	JRA-CV	
Mercury, Hg	< 0.0002	mg/L	EPA 245.1	0.002	05/18/09 15:57	05/18/09 15:57	RMD-C	
Selenium, Se	< 0.0030	mg/L	EPA 200.8	0.05	05/15/09 17:30	05/15/09 17:30	JRA-CV	
Antimony, Sb	< 0.0005	mg/L	EPA 200.8	0.006	05/19/09 17:16	05/19/09 17:16	JRA-CV	
Beryllium, Be	< 0.0005	mg/L	EPA 200.8	0.004	05/19/09 17:16	05/19/09 17:16	JRA-CV	
Nickel, Ni	< 0.0005	mg/L	EPA 200.8		05/15/09 17:30	05/15/09 17:30	JRA-CV	
Thallium, Tl	< 0.0005	mg/L	EPA 200.8	0.002	05/19/09 17:16	05/19/09 17:16	JRA-CV	
Fluoride	< 0.200	mg/L	EPA 340.2	2.2		05/21/09 0:00	SM	
Cyanide	< 0.004	mg/L	SM4500CN CI	0.2	05/14/09 14:37	05/14/09 14:37	KMS	

Approved By David M Kennedy  
 David Kennedy  
 Technical Director



**OCL Analytical Services**

35 Goshen Turnpike  
Bloomingburg NY 12721

Phone 845-733-1557

Fax 845-733-1944

Web odanalytical.com

**Certificate of Analysis**

Village of Florida  
Attn: Jim Kennedy  
P.O. Box 505, 33 S. Main St.  
Florida, NY 10921

Project NY3503527  
Date Reported  
Date Received 5/11/2009  
Date Complete 5/22/2009

Sample Number 248115-01  
Federal ID NY3503527  
Description Village of Florida  
Location Entry Point  
Sample Point

Date Sampled 05/10/09 9:00  
Sampler J. Kennedy

Test	Result	Units	Method	MCL	Prep Date	Test Date	Analyst	Qualifiers
<b>502.2 NY VOCs</b>								
Chlorobenzene	< 0.0005	mg/L	EPA 524.2	.005	05/13/09 22:19	05/13/09 22:19	DN-CV	
Chloroethane	< 0.0005	mg/L	EPA 524.2	.005	05/13/09 22:19	05/13/09 22:19	DN-CV	
Chloromethane	< 0.0005	mg/L	EPA 524.2	.005	05/13/09 22:19	05/13/09 22:19	DN-CV	
Dibromomethane	< 0.0005	mg/L	EPA 524.2	.005	05/13/09 22:19	05/13/09 22:19	DN-CV	
Dichlorodifluoromethane	< 0.0005	mg/L	EPA 524.2	.005	05/13/09 22:19	05/13/09 22:19	DN-CV	
Ethylbenzene	< 0.0005	mg/L	EPA 524.2	.005	05/13/09 22:19	05/13/09 22:19	DN-CV	
Hexachlorobutadiene	< 0.0005	mg/L	EPA 524.2	.005	05/13/09 22:19	05/13/09 22:19	DN-CV	
Isopropylbenzene	< 0.0005	mg/L	EPA 524.2	.005	05/13/09 22:19	05/13/09 22:19	DN-CV	
Methyl tert-butyl ether	< 0.0005	mg/L	EPA 524.2	.005	05/13/09 22:19	05/13/09 22:19	DN-CV	
Methylene chloride	< 0.0005	mg/L	EPA 524.2	.005	05/13/09 22:19	05/13/09 22:19	DN-CV	
Styrene	< 0.0005	mg/L	EPA 524.2	.005	05/13/09 22:19	05/13/09 22:19	DN-CV	
Tetrachloroethene	< 0.0005	mg/L	EPA 524.2	.005	05/13/09 22:19	05/13/09 22:19	DN-CV	
Toluene	< 0.0005	mg/L	EPA 524.2	.005	05/13/09 22:19	05/13/09 22:19	DN-CV	
Trichloroethene	< 0.0005	mg/L	EPA 524.2	.005	05/13/09 22:19	05/13/09 22:19	DN-CV	
Trichlorofluoromethane	< 0.0005	mg/L	EPA 524.2	.005	05/13/09 22:19	05/13/09 22:19	DN-CV	
Vinyl chloride	< 0.0005	mg/L	EPA 524.2	.005	05/13/09 22:19	05/13/09 22:19	DN-CV	
cis-1,2-Dichloroethene	< 0.0005	mg/L	EPA 524.2	.005	05/13/09 22:19	05/13/09 22:19	DN-CV	
cis-1,3-Dichloropropene	< 0.0005	mg/L	EPA 524.2	.005	05/13/09 22:19	05/13/09 22:19	DN-CV	
m,p-Xylene	< 0.0005	mg/L	EPA 524.2	.005	05/13/09 22:19	05/13/09 22:19	DN-CV	
n-Butylbenzene	< 0.0005	mg/L	EPA 524.2	.005	05/13/09 22:19	05/13/09 22:19	DN-CV	
n-Propylbenzene	< 0.0005	mg/L	EPA 524.2	.005	05/13/09 22:19	05/13/09 22:19	DN-CV	
o-Xylene	< 0.0005	mg/L	EPA 524.2	.005	05/13/09 22:19	05/13/09 22:19	DN-CV	
p-Isopropyltoluene	< 0.0005	mg/L	EPA 524.2	.005	05/13/09 22:19	05/13/09 22:19	DN-CV	
sec-Butylbenzene	< 0.0005	mg/L	EPA 524.2	.005	05/13/09 22:19	05/13/09 22:19	DN-CV	
tert-Butylbenzene	< 0.0005	mg/L	EPA 524.2	.005	05/13/09 22:19	05/13/09 22:19	DN-CV	
trans-1,2-Dichloroethene	< 0.0005	mg/L	EPA 524.2	.005	05/13/09 22:19	05/13/09 22:19	DN-CV	

CV - Benchmark Center Valley ELAP 11827  
SA - Benchmark Sayre ELAP 11216

OCL ELAP 10510

**OCL Analytical Services**

35 Goshen Turnpike  
Bloomingburg NY 12721

Phone 845-733-1557

Fax 845-733-1944

Web odanalytical.com

**Certificate of Analysis**

Village of Florida  
Attn: Jim Kennedy  
P.O. Box 505, 33 S. Main St.  
Florida, NY 10921

Project NY3503527

Date Reported

Date Received 5/11/2009

Date Complete 5/22/2009

Sample Number 248115-01  
Federal ID NY3503527  
Description Village of Florida  
Location Entry Point  
Sample Point

Date Sampled 05/10/09 9:00

Sampler J. Kennedy

Test	Result	Units	Method	MCL	Prep Date	Test Date	Analyst	Qualifiers
<b>502.2 NY VOCs</b>								
1,1,1,2-Tetrachloroethane	< 0.0005	mg/L	EPA 524.2	.005	05/13/09 22:19	05/13/09 22:19	DN-CV	
1,1,1-Trichloroethane	< 0.0005	mg/L	EPA 524.2	.005	05/13/09 22:19	05/13/09 22:19	DN-CV	
1,1,2,2-Tetrachloroethane	< 0.0005	mg/L	EPA 524.2	.005	05/13/09 22:19	05/13/09 22:19	DN-CV	
1,1,2-Trichloroethane	< 0.0005	mg/L	EPA 524.2	.005	05/13/09 22:19	05/13/09 22:19	DN-CV	
1,1-Dichloroethane	< 0.0005	mg/L	EPA 524.2	.005	05/13/09 22:19	05/13/09 22:19	DN-CV	
1,1-Dichloroethene	< 0.0005	mg/L	EPA 524.2	.005	05/13/09 22:19	05/13/09 22:19	DN-CV	
1,1-Dichloropropene	< 0.0005	mg/L	EPA 524.2	.005	05/13/09 22:19	05/13/09 22:19	DN-CV	
1,2,3-Trichlorobenzene	< 0.0005	mg/L	EPA 524.2	.005	05/13/09 22:19	05/13/09 22:19	DN-CV	
1,2,3-Trichloropropane	< 0.0005	mg/L	EPA 524.2	.005	05/13/09 22:19	05/13/09 22:19	DN-CV	
1,2,4-Trichlorobenzene	< 0.0005	mg/L	EPA 524.2	.005	05/13/09 22:19	05/13/09 22:19	DN-CV	
1,2,4-Trimethylbenzene	< 0.0005	mg/L	EPA 524.2	.005	05/13/09 22:19	05/13/09 22:19	DN-CV	
1,2-Dichlorobenzene	< 0.0005	mg/L	EPA 524.2	.005	05/13/09 22:19	05/13/09 22:19	DN-CV	
1,2-Dichloroethane	< 0.0005	mg/L	EPA 524.2	.005	05/13/09 22:19	05/13/09 22:19	DN-CV	
1,2-Dichloropropane	< 0.0005	mg/L	EPA 524.2	.005	05/13/09 22:19	05/13/09 22:19	DN-CV	
1,3,5-Trimethylbenzene	< 0.0005	mg/L	EPA 524.2	.005	05/13/09 22:19	05/13/09 22:19	DN-CV	
1,3-Dichlorobenzene	< 0.0005	mg/L	EPA 524.2	.005	05/13/09 22:19	05/13/09 22:19	DN-CV	
1,3-Dichloropropane	< 0.0005	mg/L	EPA 524.2	.005	05/13/09 22:19	05/13/09 22:19	DN-CV	
1,4-Dichlorobenzene	< 0.0005	mg/L	EPA 524.2	.005	05/13/09 22:19	05/13/09 22:19	DN-CV	
2,2-Dichloropropane	< 0.0005	mg/L	EPA 524.2	.005	05/13/09 22:19	05/13/09 22:19	DN-CV	
2-Chlorotoluene	< 0.0005	mg/L	EPA 524.2	.005	05/13/09 22:19	05/13/09 22:19	DN-CV	
4-Chlorotoluene	< 0.0005	mg/L	EPA 524.2	.005	05/13/09 22:19	05/13/09 22:19	DN-CV	
Benzene	< 0.0005	mg/L	EPA 524.2	.005	05/13/09 22:19	05/13/09 22:19	DN-CV	
Bromobenzene	< 0.0005	mg/L	EPA 524.2	.005	05/13/09 22:19	05/13/09 22:19	DN-CV	
Bromochloromethane	< 0.0005	mg/L	EPA 524.2	.005	05/13/09 22:19	05/13/09 22:19	DN-CV	
Bromomethane	< 0.0005	mg/L	EPA 524.2	.005	05/13/09 22:19	05/13/09 22:19	DN-CV	
Carbon tetrachloride	< 0.0005	mg/L	EPA 524.2	.005	05/13/09 22:19	05/13/09 22:19	DN-CV	

CV - Benchmark Center Valley ELAP 11827  
SA - Benchmark Sayre ELAP 11216

OCL ELAP 10510

COPY

**OCL Analytical Services**

35 Goshen Turnpike  
Bloomingburg NY 12721

Phone 845-733-1557

Fax 845-733-1944

Web oclanalytical.com

**Certificate of Analysis**

Village of Florida  
Attn: Jim Kennedy  
P.O. Box 505, 33 S. Main St.  
Florida, NY 10921

Project  
Date Reported 6/30/2008  
Date Received 6/16/2008  
Date Complete 6/30/2008

Sample Number 240585-01  
Federal ID 3503527  
Description Village of Florida  
Location Entry Point  
Sample Point

Date Sampled 06/16/08 7:00  
Sampler J. Kennedy

Test	Result	Units	Method	MCL	Prep Date	Test Date	Analyst	Qualifiers
<b>502.2 NY VOCs</b>								
Chloroethane	< 0.0005	mg/L	EPA 524.2		06/19/08 0:43	06/19/08 0:43		
Chloromethane	< 0.0005	mg/L	EPA 524.2		06/19/08 0:43	06/19/08 0:43		
Dibromomethane	< 0.0005	mg/L	EPA 524.2		06/19/08 0:43	06/19/08 0:43		
Dichlorodifluorometha	< 0.0005	mg/L	EPA 524.2		06/19/08 0:43	06/19/08 0:43		
Ethylbenzene	< 0.0005	mg/L	EPA 524.2		06/19/08 0:43	06/19/08 0:43		
Hexachlorobutadiene	< 0.0005	mg/L	EPA 524.2		06/19/08 0:43	06/19/08 0:43		
Isopropylbenzene	< 0.0005	mg/L	EPA 524.2		06/19/08 0:43	06/19/08 0:43		
Methyl tert-butyl ether	< 0.0005	mg/L	EPA 524.2		06/19/08 0:43	06/19/08 0:43		
Methylene chloride	< 0.0005	mg/L	EPA 524.2		06/19/08 0:43	06/19/08 0:43		
Styrene	< 0.0005	mg/L	EPA 524.2		06/19/08 0:43	06/19/08 0:43		
Tetrachloroethene	< 0.0005	mg/L	EPA 524.2		06/19/08 0:43	06/19/08 0:43		
Toluene	< 0.0005	mg/L	EPA 524.2		06/19/08 0:43	06/19/08 0:43		
Trichloroethene	< 0.0005	mg/L	EPA 524.2		06/19/08 0:43	06/19/08 0:43		
Trichlorofluoromethan	< 0.0005	mg/L	EPA 524.2		06/19/08 0:43	06/19/08 0:43		
Vinyl chloride	< 0.0005	mg/L	EPA 524.2		06/19/08 0:43	06/19/08 0:43		
cis-1,2-Dichloroethene	< 0.0005	mg/L	EPA 524.2		06/19/08 0:43	06/19/08 0:43		
cis-1,3-Dichloropropen	< 0.0005	mg/L	EPA 524.2		06/19/08 0:43	06/19/08 0:43		
m,p-Xylene	< 0.0005	mg/L	EPA 524.2		06/19/08 0:43	06/19/08 0:43		
n-Butylbenzene	< 0.0005	mg/L	EPA 524.2		06/19/08 0:43	06/19/08 0:43		
n-Propylbenzene	< 0.0005	mg/L	EPA 524.2		06/19/08 0:43	06/19/08 0:43		
o-Xylene	< 0.0005	mg/L	EPA 524.2		06/19/08 0:43	06/19/08 0:43		
p-Isopropyltoluenc	< 0.0005	mg/L	EPA 524.2		06/19/08 0:43	06/19/08 0:43		
sec-Butylbenzene	< 0.0005	mg/L	EPA 524.2		06/19/08 0:43	06/19/08 0:43		
tert-Butylbenzene	< 0.0005	mg/L	EPA 524.2		06/19/08 0:43	06/19/08 0:43		
trans-1,2-Dichloroethe	< 0.0005	mg/L	EPA 524.2		06/19/08 0:43	06/19/08 0:43		
trans-1,3-Dichloroprop	< 0.0005	mg/L	EPA 524.2		06/19/08 0:43	06/19/08 0:43		

**OCL Analytical Services**

35 Gashen Turnpike  
 Bloomingburg NY 12721

Phone 845-733-1557  
 Fax 845-733-1944  
 Web oclanalytical.com

**Certificate of Analysis**

Village of Florida  
 Attn: Jim Kennedy  
 P.O. Box 505, 33 S. Main St.  
 Florida, NY 10921

Project  
 Date Reported 6/30/2008  
 Date Received 6/16/2008  
 Date Complete 6/30/2008

Sample Number 240585-01  
 Federal ID 3503527  
 Description Village of Florida  
 Location Entry Point  
 Sample Point

Date Sampled 06/16/08 7:00  
 Sampler J. Kennedy

Test	Result	Units	Method	MCL	Prep Date	Test Date	Analyst	Qualifiers
<b>502.2 NY VOCs</b>								
1,1,1,2-Tetrachloroeth	< 0.0005	mg/L	EPA 524.2		06/19/08 0:43	06/19/08 0:43		
1,1,1-Trichloroethane	< 0.0005	mg/L	EPA 524.2		06/19/08 0:43	06/19/08 0:43		
1,1,2,2-Tetrachloroeth	< 0.0005	mg/L	EPA 524.2		06/19/08 0:43	06/19/08 0:43		
1,1,2-Trichloroethane	< 0.0005	mg/L	EPA 524.2		06/19/08 0:43	06/19/08 0:43		
1,1-Dichloroethane	< 0.0005	mg/L	EPA 524.2		06/19/08 0:43	06/19/08 0:43		
1,1-Dichloroethene	< 0.0005	mg/L	EPA 524.2		06/19/08 0:43	06/19/08 0:43		
1,1-Dichloropropene	< 0.0005	mg/L	EPA 524.2		06/19/08 0:43	06/19/08 0:43		
1,2,3-Trichlorobenzene	< 0.0005	mg/L	EPA 524.2		06/19/08 0:43	06/19/08 0:43		
1,2,3-Trichloropropane	< 0.0005	mg/L	EPA 524.2		06/19/08 0:43	06/19/08 0:43		
1,2,4-Trichlorobenzene	< 0.0005	mg/L	EPA 524.2		06/19/08 0:43	06/19/08 0:43		
1,2,4-Trimethylbenzen	< 0.0005	mg/L	EPA 524.2		06/19/08 0:43	06/19/08 0:43		
1,2-Dichlorobenzene	< 0.0005	mg/L	EPA 524.2		06/19/08 0:43	06/19/08 0:43		
1,2-Dichloroethane	< 0.0005	mg/L	EPA 524.2		06/19/08 0:43	06/19/08 0:43		
1,2-Dichloropropane	< 0.0005	mg/L	EPA 524.2		06/19/08 0:43	06/19/08 0:43		
1,3,5-Trimethylbenzen	< 0.0005	mg/L	EPA 524.2		06/19/08 0:43	06/19/08 0:43		
1,3-Dichlorobenzene	< 0.0005	mg/L	EPA 524.2		06/19/08 0:43	06/19/08 0:43		
1,3-Dichloropropane	< 0.0005	mg/L	EPA 524.2		06/19/08 0:43	06/19/08 0:43		
1,4-Dichlorobenzene	< 0.0005	mg/L	EPA 524.2		06/19/08 0:43	06/19/08 0:43		
2,2-Dichloropropane	< 0.0005	mg/L	EPA 524.2		06/19/08 0:43	06/19/08 0:43		
2-Chlorotoluene	< 0.0005	mg/L	EPA 524.2		06/19/08 0:43	06/19/08 0:43		
4-Chlorotoluene	< 0.0005	mg/L	EPA 524.2		06/19/08 0:43	06/19/08 0:43		
Benzene	< 0.0005	mg/L	EPA 524.2		06/19/08 0:43	06/19/08 0:43		
Bromobenzene	< 0.0005	mg/L	EPA 524.2		06/19/08 0:43	06/19/08 0:43		
Bromochloromethane	< 0.0005	mg/L	EPA 524.2		06/19/08 0:43	06/19/08 0:43		
Bromomethane	< 0.0005	mg/L	EPA 524.2		06/19/08 0:43	06/19/08 0:43		
Carbon tetrachloride	< 0.0005	mg/L	EPA 524.2		06/19/08 0:43	06/19/08 0:43		
Chlorobenzene	< 0.0005	mg/L	EPA 524.2		06/19/08 0:43	06/19/08 0:43		

**Village Of Florida Inc.**  
**P.O. Box 505 33 South Main Street,**  
**Florida, New York 10921**  
**Water Treatment Facilities ID# 3503527**

Date: September 22nd 2009

Orange County Department Of Health  
 M.J. Schleifer, P.E.  
 124 Main Street, Goshen, N.Y. 10924

Federal ID# 3503527

Re: Quarterly THM & HAA5 Test Results Running Average

Mr. Schleifer,

Attached please find the 3rd Quarter test results for THM's and HAA5's, for 2009.

**THM's**

Sample #	Location	2008	2009	2009	2009	
		4th Quarter	1st Quarter	2 <sup>nd</sup> Quarter	3rd Quarter	
MRT0001	Valley View	21.3 ug/l	77.4 ug/l	99.6 ug/l	112 ug/l	
DS00001	27 Rose Street	39.8 ug/l	46.6 ug/l	83.3 ug/l	124 ug/l	
DS00002	Country Chevy	84.4 ug/l	48.9 ug/l	93.9 ug/l	123 ug/l	Running
DS00003	Pharmline	48.3 ug/l	41.9 ug/l	89.2 ug/l	105 ug/l	Average
						THM's
	<b>Average:</b>	<b>48.45 ug/l</b>	<b>53.7 ug/l</b>	<b>91.5 ug/l</b>	<b>116 ug/l</b>	<b>77.41 ug/l</b>

**HAA5's**

Sample #	Location	2008	2009	2009	2009	
		4 <sup>th</sup> Quarter	1st Quarter	2 <sup>nd</sup> Quarter	3rd Quarter	
MRT0001	Valley View	1.3 ug/l	23.5 ug/l	4.6 ug/l	21.4 ug/l	
DS00001	27 Rose Street	41.4 ug/l	64.9 ug/l	48.7 ug/l	33.5 ug/l	
DS00002	Country Chevy	53.8 ug/l	54.5 ug/l	41.4 ug/l	39.7 ug/l	Running
DS00003	Pharmline	48.3 ug/l	53.3 ug/l	47.1 ug/l	33.8 ug/l	Average
						HAA5's
	<b>Average:</b>	<b>28.57 ug/l</b>	<b>49.05 ug/l</b>	<b>35.45 ug/l</b>	<b>32.1 ug/l</b>	<b>36.29 ug/l</b>

Respectfully,

James E Kennedy  
 Chief Operator

attach

**COPY**

**Village Of Florida Inc.**  
**P.O. Box 505 33 South Main Street,**  
**Florida, New York 10921**  
**Water Treatment Facilities ID# 3503527**

Date: December 29<sup>th</sup> 2008

Orange County Department Of Health  
M.J. Schleifer, P.E.  
124 Main Street, Goshen, N.Y. 10924

Federal ID# 3503527

Re: Quarterly THM & HAA5 Test Results Running Average

Mr. Schleifer,

Attached please find the 4th Quarter test results for THM's and HAA5's, for 2008.

**THM's**

Sample #	Location	2008	2008	2008	2008	
		1 <sup>st</sup> Quarter	2 <sup>nd</sup> Quarter	3rd Quarter	4th Quarter	
MRT0001	Valley View	58.5 ug/l	99.1 ug/l	68.8 ug/l	21.3 ug/l	
DS00001	27 Rose Street	40.7 ug/l	48.2 ug/l	53.5 ug/l	39.8 ug/l	
DS00002	Country Chevy	64.5 ug/l	100.8 ug/l	90.6 ug/l	84.4 ug/l	Running
DS00003	Pharmline	50.3 ug/l	74.7 ug/l	81.8 ug/l	48.3 ug/l	Average
						THM's
	<b>Average:</b>	<b>53.5 ug/l</b>	<b>80.7 ug/l</b>	<b>73.67 ug/l</b>	<b>48.45 ug/l</b>	<b>64.08 ug/l</b>

**HAA5's**

Sample #	Location	2008	2008	2008	2008	
		1 <sup>st</sup> Quarter	2 <sup>nd</sup> Quarter	3rd Quarter	4 <sup>th</sup> Quarter	
MRT0001	Valley View	39.9 ug/l	8.9 ug/l	25.6 ug/l	1.3 ug/l	
DS00001	27 Rose Street	64 ug/l	29.6 ug/l	34.2 ug/l	41.4 ug/l	
DS00002	Country Chevy	70.3 ug/l	36 ug/l	36 ug/l	53.8 ug/l	Running
DS00003	Pharmline	74.6 ug/l	30.5 ug/l	32.9 ug/l	48.3 ug/l	Average
						HAA5's
	<b>Average:</b>	<b>62.2 ug/l</b>	<b>26.25 ug/l</b>	<b>32.17 ug/l</b>	<b>28.57 ug/l</b>	<b>37.29 ug/l</b>

Respectfully,

James E Kennedy  
Chief Operator

attach

COPY

**OCL Analytical Services**

35 Goshen Turnpike  
Bloomingburg, New York 12721

**Analytical Results**OCL Sample No: **238968-01**

Page 1 of 1

Method: EPA 200.7

Analyte	Result	Units	MCL	DL	By	Notes	Prepared	Analyzed
Sodium	16.7	mg/L		0.572	GSR		04/17/2008 15:55	04/17/2008 15:55

GT = greater than  
LT = less than  
ND = not detected

MCL = maximum contaminant level  
DL = detection level

ELCD = Electrolytic Conductivity Detector (QC)  
PID = Photoionization Detector (QC)

Analysis by Eastern Lab Services #11216 (unless otherwise noted)

Printed on: 4/28/2008

**L Analytical Services**

Goshen Turnpike  
 Bloomingburg NY 12721

Phone 845-733-1557  
 Fax 845-733-1944  
 Web odanalytical.com

**Certificate of Analysis**

Village of Florida  
 Attn: Jim Kennedy  
 P.O. Box 505, 33 S. Main St.  
 Florida, NY 10921

Project NY3503527  
 Date Reported 4/22/2009  
 Date Received 4/6/2009  
 Date Complete 4/22/2009  
 Date Sampled 04/05/09 8:00  
 Sampler J. Kennedy

Sample Number 247415-01  
 Federal ID NY3503527  
 Description Village of Florida  
 Location Entry Point  
 Sample Point

Test	Result	Units	Method	MCL	Prep Date	Test Date	Analyst	Qualifiers
NA Sodium, Na	18.5	mg/L	EPA 200.7		04/16/09 19:02	04/16/09 19:02	GSR-CV	

Approved By David M Kennedy  
 David Kennedy  
 Technical Director



12006 1347

(FAA)

F.001001

**OCL Analytical Services**  
 35 Goshen Turnpike  
 Bloomingburg, NY 12721

Phone: 845-733-1557  
 Fax: 845-733-1944

Serving The Hudson Valley For Over Sixty-five Years

Printed:3/31/2008

Village of Florida  
 Attn: Jim Kennedy  
 P.O. Box 505, 33 S. Main St.  
 Florida NY 10921

Client Code: FLORIDA  
 Fed ID: 3503527

OCL Sample No : 237856

System Name : Village of Florida

Exact Location : Entry Point

Date/time Collected : 3/16/2008 9:00

Date Received : 3/17/2008

Submit By : J. Kennedy

### Analytical Results

Analysis	Result	Units	MCL	DL	Method	Lab	Date	Time	By	Remarks
Alkalinity as CaCO <sub>3</sub>	25	mg/L		None	23208	10510	03/16/08		SM	
Hardness as CaCO <sub>3</sub> , Calcium	46	mg/L		10	3500 Ca-D	10510	03/17/08	14:55	SM	
Nitrate as N	LT 0.20	mg/L	10	0.2	Lachat	10510	03/18/08		LM	

Remarks :

Copies to:

GT = greater than  
 LT = less than  
 ND = not detected

MCL = maximum contaminant level  
 DL = detection level

*J. M. Clinton*  
 Inorganic Chemistry Department  
 ELAP#10510

**OCL Analytical Services**

35 Goshen Turnpike  
 Bloomingburg NY 12721

Phone 845-733-1557  
 Fax 845-733-1944  
 Web odanalytical.com

**Certificate of Analysis**

Village of Florida  
 Attn: Jim Kennedy  
 P.O. Box 505, 33 S. Main St.  
 Florida, NY 10921

Project NY3503527  
 Date Reported 3/25/2009  
 Date Received 3/23/2009  
 Date Complete 3/25/2009

Sample Number 247079-01  
 Federal ID NY3503527  
 Description Village of Florida  
 Location Entry Point  
 Sample Point

Date Sampled 03/23/09 7:00  
 Sampler J. Kennedy

Test	Result	Units	Method	MCL	Prep Date	Test Date	Analyst	Qualifiers
NO3 Nitrate as N	<0.200	mg/L	Lachat	10.0		03/25/09 0:00	SM	

Approved By David M Kennedy  
 David Kennedy  
 Technical Director