

JUNE 2004 ADDENDUM TO JUNE 1998 DIVISION OF WATER TECHNICAL AND OPERATIONAL GUIDANCE SERIES (TOGS) NO. 1.1.1.


(Originator- Scott Stoner)

TABLE 1 NEW YORK STATE AMBIENT WATER QUALITY STANDARDS AND GUIDANCE VALUES					
SUBSTANCE (CAS No.)	WATER CLASSES	STANDARD (ug/L)	GUIDANCE VALUE (ug/L)	TYPE	BASIS CODE
Metolachlor ESA (171118-09-5)	A, A-S, AA, AA-S		50	H(WS)	Z
	GA		50	H(WS)	Z
Metolachlor OA (152019-73-3)	A, A-S, AA, AA-S		50	H(WS)	Z
	GA		50	H(WS)	Z
Propylene glycol (57-55-6)	A, A-S, AA, AA-S		*	H(WS)	G
	GA		*	H(WS)	G

Remark \*Guidance value is 1,000 ug/L except that a guidance value of 300 ug/L applies at the point of intake of a public or private water supply that uses ozonation in its treatment process.

TABLE 5 NEW YORK STATE GROUNDWATER EFFLUENT LIMITATIONS (CLASS GA)		
SUBSTANCE (CAS No.)	MAXIMUM ALLOWABLE CONCENTRATION (ug/L)	CATEGORY
Metolachlor ESA (171118-09-5)	50	B
Metolachlor OA (152019-73-3)	50	B
Propylene glycol (57-55-6)	1,000	B

In addition, metolachlor and propylene glycol are deleted from Table 3 of the June 1998 edition of TOGS 1.1.1.



Sandra L. Allen, Director  
Division of Water